



Product Service

Attestation of Conformity

No. E8A 107556 0044 Rev. 00

Holder of Attestation: **SUZHOU VEICHI ELECTRIC CO.,LTD**
No.1000 Songjia Avenue, Guoxiang Street
Wuzhong District
215124 Suzhou
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Electronic frequency converter
(AC Drive)**

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64713243037401

Date, 2024-08-14

(Tony Liu)

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. E8A 107556 0044 Rev. 00

Model(s): AC310-T3-004G/5R5P-B-I(a), AC310-T3-5R5G/7R5P-B-I(a), AC310-T/S2-2R2G-B-I(a), AC310-T/S2-004G-B-I(a), AC310-T3-004G/5R5P-B(a), AC310-T3-5R5G/7R5P-B(a), AC310-T/S2-2R2G-B(a), AC310-T/S2-004G-B(a)
Remark: “(a)” The model number may include a suffix “XXXXXXXXXX”, where “XXXXXXXXXX” can be blank or combination of any alphanumeric and/or symbols that represents customer identity

Description of Object:

Rated Input:	See below Table 1-Model list
Rated Output:	See below Table 1-Model list
Construction:	Built-in
Remark: - When installing the equipment, all requirements of the mentioned standard must be fulfilled and it should be suitably installed in closed electrical operation area, and fire/mechanical protection enclosure shall be provided. - For safe operation, a suitable external circuit breaker or fuse must be employed before installation.	

Environments:C3 and industrial enviroments



Product Service

Attestation of Conformity

No. E8A 107556 0044 Rev. 00

Table 1- Model list		
Model No.	Rated Input	Rated Output
AC310-T3-004G/5R5P-B-I(a)	3PH AC380V-480V 13.3A 50Hz/60Hz	3PH 4/5.5KW 0V-input 10/13A 0Hz-600Hz
AC310-T3-5R5G/7R5P-B-I(a)	3PH AC380V-480V 17.2A 50Hz/60Hz	3PH 5.5/7.5KW 0V-input 13/17A 0Hz-600Hz
AC310-T/S2-2R2G-B-I(a)	1/3PH AC200V-240V 23.5A 50Hz/60Hz	3PH 2.2KW 0V-input 10A 0Hz-600Hz
AC310-T/S2-004G-B-I(a)	1/3PH AC200V-240V 37.1/21.4 50Hz/60Hz	3PH 4KW 0V-input 16A 0Hz- 600Hz
AC310-T3-004G/5R5P-B(a)	3PH AC380V-480V 13.3A 50Hz/60Hz	3PH 4/5.5KW 0V-input 10/13A 0Hz-600Hz
AC310-T3-5R5G/7R5P-B(a)	3PH AC380V-480V 17.2A 50Hz/60Hz	3PH 5.5/7.5KW 0V-input 13/17A 0Hz-600Hz
AC310-T/S2-2R2G-B(a)	1/3PH AC200V-240V 23.5A 50Hz/60Hz	3PH 2.2KW 0V-input 10A 0Hz-600Hz
AC310-T/S2-004G-B(a)	1/3PH AC200V-240V 37.1/21.4 50Hz/60Hz	3PH 4KW 0V-input 16A 0Hz- 600Hz
Remark: CANopen communication card: AC300CAN1		

Tested according to:

EN IEC 61800-3:2023

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.